

2020 Water Quality Report
MILFORD WATER DEPARTMENT
180 Vickers Drive, Milford, DE 19963
PWS ID# DE0000616
May 12, 2021

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with this information because informed customers are our best allies.

Spanish (Español): Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúscalo o hable con alguien que lo entienda bien.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Your water is groundwater that comes from the Frederica, Federalsburg and Milford Aquifers.

Source water assessment and availability

Our source water assessment is available through: <http://delawaresourcewater.org/assessments/>

The Source Water Assessment's Summary of Our System's Susceptibility to Contamination

Milford Water Department Public Water System is exceedingly susceptible for pathogens, metals and other inorganic compounds. It has a high susceptibility rating for nutrients, petroleum hydrocarbons, pesticides, PCBs and other organic compounds.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline, 800-426-4791.

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

How can I get involved?

If you have any questions about this report or concerning your water utility, please contact Steve Ellingsworth at 302-270-5265. If you want to learn more about your water utility, please attend our meetings held the 2nd & 4th Monday of each month at 7:00 pm at City Hall, 201 S. Walnut Street, Milford, DE 19963. We want our valued customers to be informed about their water utility.

Additional information about lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Milford Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at: <http://www.epa.gov/safewater/lead>

Violations:

2020 – MCL Average Fluoride – Water samples showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) from 06/23/2020 to 07/22/2020.

Additional information about fluoride

Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.

For more information, contact:

Steve Ellingsworth
Milford Water Department
180 Vickers Drive, Milford, DE 19963
(302) 270-5265

Water Quality Data Tables

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions in the tables below.

Definitions

| Unit Descriptions | |
|-------------------|--|
| Term | Definition |
| ppm | ppm: parts per million, or milligrams per liter (mg/L) |
| ppb | ppb: parts per billion, or micrograms per liter (µg/L) |
| NA | NA: not applicable |
| ND | ND: Not detected |
| NR | NR: Monitoring not required, but recommended. |

| Important Drinking Water Definitions | |
|--------------------------------------|---|
| Term | Definition |
| MCLG | MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MCL | MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| SMCL | SMCL: Suggested Maximum Contaminant Level for aesthetic contaminants. |
| TT | TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water. |
| AL | AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| MRDLG | MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MRDL | MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |

Table of Regulated Contaminants Utilizing 2020 Test Results

| Lead and Copper | Units | MCLG | AL | 90 th Percentile | # sites over AL | Sample Date | Violation | Typical Source of Contamination |
|---|-------|---------|--------|-----------------------------|-----------------|-------------|-----------|---|
| Lead | ppb | 0 | 15 | 1.2 | 0 | 2019 | No | Corrosion of household plumbing systems; erosion of natural deposits |
| Copper | ppm | 1.3 | 1.3 | 0.041 | 0 | 2019 | No | Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing system. |
| Regulated Contaminants | Units | MCLG | MCL | Highest Level | Range | Sample Date | Violation | Typical Source of Contamination |
| Haloacetic acids (HAA5) | ppb | n/a | 60 | 8 | 6.206-10.279 | 2020 | No | By-product of drinking water chlorination |
| Total Trihalomethanes (TTHM) | ppb | n/a | 80 | 21 | 9.6-31.66 | 2020 | No | By-product of drinking water disinfection |
| Chlorine | ppm | MRDLG 4 | MRDL 4 | 1.48 | 0.46-1.48 | 2020 | No | Water additive to control microbes. |
| Fluoride | ppm | 2 | 2 | 3 | 0.0843-3.69 | 2020 | Yes | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| Cyanide | ppb | 200 | 200 | 161 | 0-161 | 2020 | No | Discharge from plastic and fertilizer factories; Discharge from steel/metal factories. |
| Nitrate (measured as Nitrogen) | ppm | 10 | 10 | 3.501 | 0-3.501 | 2020 | No | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Nitrite (measured as nitrogen) | ppm | 1 | 1 | 0.228 | 0-0.228 | 2020 | No | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Combined Radium 226/228 | pCi/L | 0 | 5 | 2 | 0.82-2.4 | 2020 | No | Erosion of natural deposits. |
| Gross alpha excluding radon and uranium | pCi/L | 0 | 15 | 3.3 | 0.96-3.3 | 2020 | No | Erosion of natural deposits. |

Delaware Secondary Drinking Water Standards

| Contaminants | Units | State SMCL | Average | Range |
|--------------|-------|------------|---------|-----------------|
| Alkalinity | ppm | n/a | 166.88 | 154-179 |
| Chloride | ppm | 250 | 6.66 | 4.0962-15.9069 |
| Iron | ppb | 300 | 0.02 | 0-0.1536 |
| Manganese | ppb | 50 | 0.021 | 0.01807-0.03795 |
| Sodium | ppm | n/a | 19.223 | 10.74-42.31 |
| Sulfate | ppm | 250 | 3.263 | 1.2135-15.3962 |

We, at Milford Water Department, work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

This CCR Report was prepared in collaboration with Delaware Rural Water Association and Milford Water Department.

